

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 8110-2135:0100 Page 1 of 1

**CATEGORY:** 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I)

**LISTEE:** Thermory USA LLC 1213 Wilmette Avenue, Suite 208, Wilmette, IL 60091  
Contact: Mark Challinor (847) 256-8828  
Email: mark@thermoryusa.com

**DESIGN:** Thermally-Modified Ash Deck Boards with dimensions of 3/4' x 5-7/8" or 1.02" x 5.7" with a maximum of 3/16" edge-to-edge spacing.  
Refer to the manufacturer's installation instructions and product data sheets.

**RATING:** Class B Flame Spread

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee name, Model number, rating and SFM label.

**APPROVAL:** Listed as wood decking materials for use in the Wildland Urban Interface areas. Refer to manufacturer's Installation Manual for details.

**NOTE:** Test Protocol SFM-12-7A-4A

09-25-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

*Listing Expires* **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*