



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

| | |
|----------------------|---|
| LISTING No.: | 8110-2135:0100 |
| CATEGORY: | 8110 - DECKING FOR WILDLAND URBAN INTERFACE (W.U.I) |
| LISTEE: | Thermory USA LLC 1213 Wilmette Avenue, Suite 208, Wilmette, IL, 60091 Contact: Challinor, Mark (847) 256-8828 Email: mark@thermoryusa.com |
| DESIGN: | Thermally-Modified Ash Deck Boards with dimensions of 3/4' x 5-7/8" or 1.02" x 5.7" with a maximum of 3/16" edge-to-edge spacing. Refer to the manufacturer's installation instructions and product data sheets. |
| RATING: | Class B Flame Spread |
| INSTALLATION: | In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. |
| MARKING: | Listee name, Model number, rating and SFM label. |
| APPROVAL: | Listed as wood decking materials for use in the Wildland Urban Interface areas. Refer to manufacturer's Installation Manual for details. |
| NOTES: | Test Protocol SFM-12-7A-4A |

09-25-13 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/05/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division